



Aquastat:  
Run call to  
boiler through  
N.C. contacts  
to break at 150  
- 160

Steam Boiler  
Take Supply and  
Return tapings off  
below water line

HEAT EXCHANGER  
NEEDED TO ALLOW  
FOR PRESSURIZED  
RADIANT SIDE

**CAPCO**  
ENERGY SUPPLY, INC.

781-721-0303 FAX 781-721-9119 WWW.CAPCOSUPPLY.COM

10 INDUSTRIAL PARKWAY  
WOBURN MA 01801

RADIANT OFF OF STEAM  
BOILER

NLC  
11.9.09

THIS IS ONLY A CONCEPT DRAWING. ALL CONDITIONS AND NECESSARY COMPONENTS MUST BE FIELD VERIFIED AND ARE THE RESPONSIBILITY OF THE INSTALLING CONTRACTOR